



Office of the Water Authority

Immigration Tower
7 Gloucester Road
Hong Kong

Telephone 829 4446

電 話

Facsimile 824 0578

傳 真

Reference (10) in WWO 2209/32 XIV

檔 號

水務監督辦事處

香港灣仔
倫士打道七號
入境入境事務大樓

Date 23 November 1994
日期

IPM Limited,
10/F., United Success Commercial Bldg.,
506 Jaffe Road,
Causeway Bay,
Hong Kong

Attn: Miss Jimmy Pang

Dear Madam,

Re: "PAGLER" Equilibrium Float Valve - 901

Your previous letters, the latest one dated 19th November 1994 refer.

It is noted that the fittings described below have been examined, tested and accepted by the Water Research Centre (WRC) to have complied with the United Kingdom Water Bylaws Scheme when correctly installed :-

VALVES

2100

Float operated - Equilibrium Metal.

Range of Equilibrium float operated valves (for Hot and cold water use) of right angle pattern with gunmetal body (IG2) seating disk and cap and disk guide and having a rubber EPDM disk face. Provided with floats manufactured from copper. Maximum working pressure 10 bar.

Product Designation: Pagler Pattern, 901 - 1in - 6in (Threaded)

Marking: Body embossed valve size, Fig No and manufacturer's name "Pagler"

Manufacturer: Pagler Limited (Manufacturer)

WRC Directory
Reference No.

9401071

IRN 001, 136

- 2 -

In view of the acceptance by WRC, I have no objection to the use of the above fittings in water supply plumbing system subject to full adherence to waterworks installation requirements.

A condition of this acceptance is that fittings to be installed should be replicas of the samples certified by WRC and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in water supply plumbing systems.

In applying for the use of the fittings in any project the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Yours faithfully,



(CHAN Chi-chiu)
for Water Authority