



水務監督辦事處
Office of the Water Authority

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

HOKLAS
HONG KONG
Registration No. 0 & 74

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4446

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/00 Pt. 1 T/J(149)

8 August 2000

Gate Way Valve & Fitting Ltd.
Flat F, 22/F., Luk Hop Industrial Building,
8 Luk Hop Street, San Po Kong,
Hong Kong.

(Attn: Mr. Jack T. K. HO)

Dear Sirs,

Approval of "AVK" Cast Iron Gate Valves

Your letter ref. WA-F00101 dated 21 July 2000 refers.

Having considered the test reports by the Nutek Systems, Ltd. this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: AVK International A/S

Country of Origin: Denmark

Brand: AVK

Details of Fittings: 50, 65, 80, 100, 150, 200, 250, 300, 350 and 400mm
Cast iron gate valves to BS 5163 Type A, with
handwheels for on/off operation, flanged to BS4504
PN16, internally and externally coated with epoxy
approved by WRc Directory Reference No. 9502507.
Pressure Rating PN16.

Model No: 02-40

Body Markings: for DN 50 GG

AVK
DN50
PN16 CI

Acceptance Reference No. C20000058

Page: 1

水務署化驗室及水錶測試實驗室均已獲得香港實驗所認可計劃確認可進行特定試驗項目並載列於「認可計劃」的認可實驗室名冊內。

Chemical and Meter Testing Laboratories of the Water Supplies Department are accredited by HOKLAS for specific tests as listed in the HOKLAS Directory of Accredited Laboratories.

for DN65 CI
 AVK
 DN65
 PN16

for DN80 to DN300
 AVK
 DNSS
 PN16
 GG
 CI
("SS" denotes 80, 100, 150, 200,
250 or 300.)

for DN350 and DN400
 AVK
 SSS
 PN16
 GG
("SSS" denotes 350 or 400.)

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

In applying for the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Yours faithfully,



(CHAU Chi-wai, David)
for Water Authority