



Office of the Water Authority

Immigration Tower
7 Gloucester Road
Hong Kong

水務監督辦事處

香港灣仔
吉士打道七號
人民入境事務大樓

Telephone

電話 2829 4446

Facsimile

圖文傳真 2824 0578

Reference

檔號 (2) in WSD 3321/97 Pt.2 T/J (17)

Date

日期 29 July 1997

Dear Sirs,

Approval of "AVK" Gate Valve Series 21

Your letter ref. F27166/KFC dated 14 July 1997 refers.

It is noted that the fitting described below has been examined, tested and accepted by the Water Research Centre (WRC) to have complied with the United Kingdom Water Bylaws Scheme when correctly installed:-

Name of Manufacturer: Aqua-Gas Manufacturing Ltd

Country of Origin: U. K.

Name of Brand: AVK

Details of Fitting: 'AVK Series 21' range of gate valves having either a grey or a ductile iron body & bonnet and a ductile iron gland flange, all being epoxy resin coated (HB Fuller 9502507 Blue) having a ductile iron gate/wedge which is encapsulated with EPDM (EDJ70). Manufactured in accordance with BS 5163:1986 and having stainless steel stems.

Working Pressure: Maximum working pressure 16 bar.

Size: 50 - 400mm

Product Designation: Series 21

Marking: Body embossed "AVK", valve size, pressure rating and identification code. Adhesive label on valve top flange indicates "BS5163 PN16 70°C and ID code.


WRc Directory Ref. No: 9702008 IRN 001

In view of the acceptance by WRc, I have no objection to the use of the said fitting in fresh water supply plumbing system subject to full adherence to waterworks installation requirements.

A condition of this acceptance is that fitting to be installed should be replicas of the sample certified by WRc and no modification should be made to the fitting. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water supply plumbing systems.

In applying for the use of the fitting in any project the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Yours faithfully,



(CHAN Chi-chiu)
for Water Authority